updated 2022-04-18
updated 2024-01-16
updated 2024-06-26 after power outage

room	rack	UPS	feeds	Amps	UPS in service date	Battery Date?	replacement battery pack type	
323	tall wall	TrippLite 1500XL non-RM	FreeBSD+?	30		died power outage 2024-06-26?	TrippLite RBC48 SUTWR	
323	left of tall wall	APC SRT1500XLA	non-FreeBSD	15	2024-07-09	2024-07-09		
323	tall wall	APC SmartUPS 1500 non-RM	non-FreeBSD and FreeBSD	15		2023-09-01	RBC7, bought another in 2024-07	
323	tall wall	Rackmount 1500 temporary	ns1	15?	2024-01-06	2024-01-06		eventually will go elsewhere
323	on floor not installed	extended runtime UPS + external btty	ns1	15?	future			
323	short center	TrippLite SMART3000RM2U	truenas3, esx4,5,6, +	30		ok?	RBC94-2U	
323	short center	APC SmartUPS 3000 2U RM	truenas3, esx4,5,6, +	30		ok	RBC43	
323	aging backup	SmartUPS 3000 2U RM		30	2024-01-16	2024-01-16		
323								
323	corner network	new 750VA	switches, small servers, etc		2023-02-11	2023-02-11		for other network stuff
323	genetics window	APC SmartUPS 3000 2U		30		2022-07-15	RBC43	
323	genetics window	APC SmartUPS 3000 2U	TESTING	30	old	2024-01-16	RBC43	UPS used to be in 423 with no b
telephone room off kitchen	floor	TrippLite SU2200XL	router, fortinet, switches	15	2022-07-15	2022-07-15		
telephone room off kitchen	floor	TrippLite SU1000XL	router, fortinet, switches	15	2022-07-15	2022-07-15		
423	West	APC SmartUPS DLA3000RM2U	423boot	15?		2022-08-22	RBC43	
423	North center	TrippLite BP48V24-2U	agetruenas3			ok		
423	North East	APC SmartUPS 3000 2U	agesas2,...		2024-01-16	2024-01-16	RBC43	
423	South West	TrippLite SmartUPS 3000RM2U	agetruenas7	30		PASS		
423	South Center	APC SUA1500RM2U	age5			1905-07-09	RBC24-UPC - we have one in the back	replace this UPS
423	South East	APC SUA2200R2X180		30		2024-01-16	RBC43	replaced BTTY
423	South East	APC SmartUPS 3000 2U		30	2024-01-16	2024-01-16	RBC43	replaced UPS
							RBC96-3U	for a UPS we no longer have

TrippLite 3000 2U RM batteries:

Verify your battery configuration by checking the batteries inside the UPS. If your battery configuration looks like the photo for RBC94-2U (see link above), use one (1) RBC94-2U unit. If the battery set does not look like this, you will need one (1) RBC54 unit.

ɔtty at all